



Development Bank of the Philippines

REQUEST FOR QUOTATION

Date

Sir/Madame:

Please quote your lowest price on the item as specified below with an Approved Budget of P 200,000.00 and submit your quotation signed by your representative not later than [09/24/2020].

Thank you.

FROM:

JENRAY P. BANQUILING
ADMINISTRATIVE ASSISTANT

- NOTE: 1. Quotation shall include fees, taxes, and other charges
2. Please enclose the requested quotation in a sealed envelope and submit the same, on this address: DBP Cotabato Br., Cotabato City, [/ /].
3. The winning bidder shall be required to submit the following documents: Mayor's/Business Permit, PhilGEPS Reg. Number, Income/Business Tax Return, Professional License, PCAB License and Omnibus Sworn Statement (if applicable). The failure to do so shall result in their disqualification.
4. DBP reserves the right to reject any and all quotations, to waive any defect in them and to award to the bidder whose price quotation is deemed most advantageous to the Bank.

For any queries, please feel free to contact the following:

- 1. DELOS A. MARTINEZ JR, Branch Head, [Tel. No. 421-2368]
2. JENRAY P. BANQUILING, Branch's Point Person [Tel. No. 421-2368]

Table with 5 columns: ITEM QTY, UNIT, ARTICLES / DESCRIPTION, UNIT PRICE, TOTAL AMOUNT. Row 1: 1, unit, 3-TONNER AIR-CONDITIONER, To be delivered at DBP Cotabato Br., Cotabato City, on [/ /], Note: Please refer to attached Technical Specifications for more details, Terms: Prices are inclusive of VAT, Delivery and Installation, One Year Warranty on Parts and Labor.

COMPANY NAME: _____
ADDRESS: _____
CONTACT PERSON: _____
CONTACT NUMBER: _____
SIGNATURE: _____


TECHNICAL SPECIFICATION
3TR FLOOR STAND INVERTER TYPE AIR-CONDITION

SPECIFICATION	
> CAPACITY	> 3.0TR
> COOLING CAPACITY	> 36,160 (Kj/h)
> POWER INPUT	> 3,300 WATTS
> POWER SOURCE	> 200 V / 1 PH / 60Hz
> RUNNING CURRENT	> 15.0 AMP
> EER	> 11.6
> REFRIGERANT	> 410A; 407; 32

PREPARED BY:


MGR. NORL E. ALIMUIN
Repairs and Maintenance Unit

APPROVED:


VP ROMEO A. AGUILAR
Head, CFMD