

**REQUEST FOR QUOTATION**

The Development Bank of the Philippines (DBP), through its Northern Luzon – Regional Bids and Awards Committee (RBAC), will undertake a Small Value Procurement for the **“Supply, Delivery, Installation, and Testing of One (1) Unit Burglar Alarm Control Panel”** in accordance with Section 53.9 of the Revised Implementing Rules and Regulations of Republic Act No. 9184.

The details of the project/activity/program are as follows:



Name of Project	: <b>Supply, Delivery, Installation, and Testing of One (1) Unit Burglar Alarm Control Panel</b>
Delivery Address	: DBP Vigan Branch, L. Florentino St., Vigan City, Ilocos Sur
Approved Budget for the Contract	: Seventy Thousand Pesos (P70,000.00) inclusive of delivery of unit and taxes
Payment Terms	: Processing of full payment shall only proceed upon complete delivery and successful installation
Specification	: See attached Annex “A” for complete specifications
Delivery Period	: Within fifteen (15) calendar days upon signing of Purchase Order

Interested suppliers are required to submit their signed Price Quotation Form (Annex “B”) on or before 3:00 P.M. of September 17, 2021. Open quotations may be submitted manually at DBP Branch Banking Group – Northern Luzon, Lower Session Road, Baguio City or through email address [nlbg@dbp.ph](mailto:nlbg@dbp.ph) and [axpcacho@dbp.ph](mailto:axpcacho@dbp.ph).

The project shall be awarded to the proponent determined to have submitted the Single or Lowest Calculated and Responsive Quotation. The proponent with the lowest and responsive quotation shall be required to submit to the BAC certified copies of the following documents before award of the project:

1. Mayor’s / Business Permit
2. PhilGEPS Registration
3. Omnibus Sworn Statement

For inquiry, you may contact SM Marjorie Anne R. Muñoz at Telephone Nos. (077) 674-2502 / 674-2503 or (02) 8818-9511 local 1561.

  
**FVP MARIA DOLORES C. GUEVARA**  
Head of the Procuring Entity 






## ANNEX A

### TECHNICAL SPECIFICATIONS


#### TECHNICAL SPECIFICATION BURGLAR ALARM CONTROL PANEL

Specification	
One (1) Unit	
Power Supply	230vAC, 60Hz, 0.75A.
Battery	
Charging Capacity	7-33AH Larger battery will require a separate cabinet
Communication Loop	Supervised
Notification Appliance Circuits	Terminal Strip provides connections Maximum signaling current 2.0 A End-of-line resistor: 4.7 KOhm, ½ watt
Standby Current	135 mA
Alarm Current	220 mA
Aux Power Circuit	1.0A @ 24 VDC per circuit, power-limited
Two Programmable Relays and One Fixed Trouble Relay	Contact rating: 2.5 A @24VDC (resistive) Form-C relay, non power-limited, non supervised
LED Indicators	AC Power green Supervisory (yellow) Alarm Silenced (yellow) System trouble (Yellow) Disable (Yellow)
Keypad Controls	Acknowledge Silence Drill System Reset (Lamp test) 10-key numeric keypad 5 Zone Disable 2 NACs disable keypad

Prepared by:

  
MGR. NOEL E. ALIMUIN  
Repairs and Maintenance Unit

APPROVED:

  
VP ROMEO A. AGUILAR  
Head, CFMD



**ANNEX B**

**PRICE QUOTATION FORM**

\_\_\_\_\_  
(Date)

**The Regional Bids and Awards Committee**  
Northern Luzon  
Development Bank of the Philippines  
Lower Session Road, Baguio City

Sir/Madam:

After having carefully read and accepted the terms and conditions in the Request for Quotation and Terms of Reference, hereunder is our quotation for the items as follows:

Description	Qty	Unit	Unit Cost	Total Price
Supply, Delivery, Installation, and Testing of Burglar Alarm Control Panel	1	Unit		
TOTAL				
Amount in words				

The above-quoted price is inclusive of applicable taxes.

\_\_\_\_\_  
Name of Company / Business

\_\_\_\_\_  
Address of Company

\_\_\_\_\_  
Signature over printed name of Owner /  
Authorized Representative

\_\_\_\_\_  
Contact Number