

**SUPPLEMENTAL BID BULLETIN NO. 1**

26 November 2021

Attention: **All prospective bidders for the project**

BID REFERENCE NO. G-2021-46: SUPPLY AND DELIVERY OF FOUR HUNDRED FIFTY (450) UNITS OF 2KVA UPS FOR THE DEVELOPMENT BANK OF THE PHILIPPINES
(ABC: PhP20,250,000.00 inclusive of all applicable taxes)

Please be informed of the following:

1. **The schedule for the Deadline of Submission and Receipt, and Opening of Bids is revised as follows:**

ACTIVITY	DATE AND TIME		VENUE
	FROM	TO	
Deadline for the Submission of Eligibility, Technical, and Financial Documents	02 December 2020 (Thursday) On or before 09:00 AM	09 December 2020 (Thursday) <u>On or before 09:00 AM*</u>	6/F BAC Secretariat, DBP Head Office, Makati City
Opening of Eligibility, Technical, and Financial Documents	02 December 2020 (Thursday) 09:30 AM	09 December 2020 (Thursday) 09:30 AM	12/F Executive Staff Room, DBP Head Office, Makati City and via Zoom Meeting

***Late Bids shall not be accepted**

2. **Please refer to the Section III. Bid Data Sheet (BDS) for the detailed procedure and options for the payment of bidding documents, submission and opening of bids. As indicated in the Invitation to Bid, bidders must secure the required payment for the bidding documents on or before the deadline of the submission and receipt of bids. Bidders are encouraged to attend the bid opening through Zoom Meeting App.**
3. **Replies to queries of the bidders:**

QUERY/CONCERN	CLARIFICATION
From Bidder 1: For runtime technical specifications, 15 minutes at full load. Is the full load pertains to ATM load? Are we going to use ATM load to test the back-up time of 15 minutes?	Yes, 15 minutes at ATM full load.
Is the installation of the UPS by the supplier still required since it can be installed easily by anyone because the 2KVA UPS is a plug and play unit?	Yes, to ensure that the delivered unit is in good and working condition.



QUERY/CONCERN	CLARIFICATION
Regarding TAB 12 requirement, can we submit equivalent document for Energy Star compliant. Equivalent certificate like CE or Since the UPS brand is our own brand (OEM) and the brand is not sold in other countries, will you accept certification from the manufacturer that it is energy star compliant.	<p>Conformity of European (CE) certificate is acceptable in lieu of the Energy Star Certification.</p> <p>The requirement for TAB 12 is amended. Please see REVISED FORM 8 for the Revised Technical Specifications and ANNEX A for the Revised Checklist of Requirements attached in this Supplemental Bid Bulletin No. 1 dated 26 November 2021.</p>
Regarding TAB 17, can we submit Certificate of Satisfactory Performance?	Yes, we require Certificate of Performance Evaluation with at least Satisfactory rating.
This is to request clear copy of Distribution List Form 8-A	<p>The complete Distribution List is provided in this Supplemental Bid Bulletin.</p> <p>Please see REVISED FORM 8-A attached in this Supplemental Bid Bulletin No. 1 dated 26 November 2021.</p>
Please confirm delivery address of the 450 units is direct to the branch or in DBP Head office.	Delivery is directly to the branches as listed in REVISED FORM 8-A .
From Bidder 2:	
Can we provide an equivalent certificate like CE?	<p>Conformity of European (CE) certificate is acceptable in lieu of the Energy Star Certification.</p> <p>Please see REVISED FORM 8 for the Revised Technical Specifications and ANNEX A for the Revised Checklist of Requirements attached in this Supplemental Bid Bulletin No. 1 dated 26 November 2021.</p>
Can we provide Certificate of Acceptance as an alternative for Certificate of Performance Evaluation?	No. We require Certificate of Performance Evaluation with at least Satisfactory rating.
For TAB 16, we have been in the business for 32 years catering to the needs of our clients nationwide. We are supplying our owned registered brand and trademarks of various UPS & Batteries (see attached certifications) and providing services for both after-sales and maintenance to Government and Private entities such as banks, hospitals, ATM and so on. Furthermore, we assigned well-trained and directly employed Field Engineers as functioning as our Field Operating Centers (FOC's) situated in strategic key cities and regions nationwide – From Batanes to Tawi-tawi-24 hours a day, 7days a week. Additionally, it also serves as our storage back-up units such as batteries and UPS, which commonly used for ATMs. These engineers have been trained here and abroad and are periodically re-trained to	The requirement is list of bidder or brand's accredited service center. The bidder must have service centers where DBP Branch Banking Groups and Lending Center Groups are located within the region.