



## SUPPLEMENTAL BID BULLETIN NO. 2

12 January 2022

Attention: All prospective bidders for the project

**BID REFERENCE NO. G-2021-52: SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF REPLACEMENT PARTS/COMPONENTS FOR THE REPAIR OF THE FIRE SUPPRESSION SYSTEM AND FIRE DETECTION ALARM SYSTEM OF THE BAGUIO BUILDING OF THE DEVELOPMENT BANK OF THE PHILIPPINES – REBID (ABC: PhP 1,500,000.00 inclusive of all applicable taxes)**

Please be informed of the following:

1. The schedule for the Deadline of Submission and Receipt, and Opening of Bids shall proceed as follows:

ACTIVITY	DATE AND TIME (Per Supplemental Bid Bulletin No. 1 dated 14 December 2021)	VENUE
Deadline for the Submission and Receipt of Eligibility, Technical and Financial Proposals	<b>20 January 2022 (Thursday) <u>On or before 09:00 AM*</u></b>	6/F BAC Secretariat, DBP Head Office, Makati City
Opening of Eligibility, Technical and Financial Proposals	<b>20 January 2022 (Thursday) 10:30 AM</b>	12/F Executive Staff Room, DBP Head Office, Makati City and via Zoom Meeting

***\*Late Bids shall not be accepted***

2. Please refer to the Section III. Bid Data Sheet (BDS) for the detailed procedure and options for the payment of bidding documents, submission and opening of bids. As indicated in the Invitation to Bid, bidders must secure the required payment for the bidding documents on or before the deadline of the submission and receipt of bids. **Bidders are encouraged to attend the bid opening through Zoom Meeting App.**

3. Replies to queries of the bidders during the Pre-bid Conference:

QUERY/CONCERN	CLARIFICATION
What is the sprinkle-head's size?	The Sprinkle Head's size is 1-inch diameter pipe.  Please see <b>REVISED FORM 8</b> for the <b>Revised Technical Specifications</b> and <b>ANNEX A</b> for the <b>Revised Checklist of Requirements</b> attached in this Supplemental Bid Bulletin No. 1 dated 12 January 2022.
Is this project replacement of old sprinkler heads or setting-up of new sprinklers?	Replacement of heads only.
Will the TWG accept fabricated annunciators? There are no ready-made annunciators in the market.	Submission of fabricated annunciators is allowed.
Certain bidders have Category B PCAB license, will they be allowed to participate?	PCAB License is not required for this project.  Please see <b>REVISED FORM 8</b> for the <b>Revised Technical Specifications</b> and <b>ANNEX A</b> for the <b>Revised Checklist of Requirements</b> attached in this Supplemental Bid Bulletin No. 1 dated 12 January 2022.
For the Fire Detection Alarm System, if the system is not compliant with the requirement but compliant with the IRR of the fire code, will prospective bidders be allowed to participate?	Bidders will be allowed to participate as long as the system is compliant with the IRR of RA 9514 or the Revised Fire Code of the Philippines.

4. Revised Bidding Form:

FROM	TO
FORM 8  Technical Specifications	REVISED FORM 8  Revised Technical Specifications  <i>(Attached in this Supplemental Bid Bulletin No. 2 dated 12 January 2022)</i>