

**SUPPLEMENTAL BID BULLETIN NO. 1**

23 February 2022

Attention: **All prospective bidders for the project**

BID REFERENCE NO. G-2022-06: COMPLETE DUST ELIMINATION, CLEANING, AND DECONTAMINATION OF SUPPLY/RETURN AIR DUCT SYSTEM AND CEILING RETURN PLENUM OF THE MAIN AND ANNEX BUILDING OF THE DEVELOPMENT BANK OF THE PHILIPPINES - REBID
(ABC: PhP 2,000,000.00 inclusive of all applicable taxes)

Please be informed of the following:

1. **The schedule for the submission and opening of bids shall proceed as follows:**

ACTIVITY	DATE AND TIME	VENUE
Deadline for the Submission of Eligibility, Technical and Financial Proposals	03 March 2022 (Thursday) <u>On or before 09:00 AM*</u>	6/F BAC Secretariat, DBP Head Office, Makati City
Opening of Eligibility, Technical and Financial Proposals	03 March 2022 (Thursday) 10:15 AM	12/F Executive Staff Room, DBP Head Office, Makati City and via Zoom Meeting

***Late Bids shall not be accepted.**

2. **Please refer to the Section III. Bid Data Sheet (BDS) for the detailed procedure and options for the payment of bidding documents, submission and opening of bids. As indicated in the Invitation to Bid, bidders must secure the required payment for the bidding documents on or before the deadline of the submission and receipt of bids. Bidders are encouraged to attend the bid opening through Zoom Meeting App.**


3. **Replies to queries of the bidders:**

QUERY/CONCERN	CLARIFICATION
In lieu of the Mineral Dusts, we wish to recommend the IAQ test that will measure the Particulate Matter (PM). Particulate matter is the most common airborne pollutants found outside and inside the building. It is a mixture of solid particles and liquid droplets suspended in the air, such as dust, pollen, smoke and soot. Outdoor PM, generated by construction, for example, or the burning of fossil fuels, enters into buildings via natural and mechanical ventilation while Indoor PM can be	<p>No. We retain the requirement on Mineral Dusts.</p> <p>Advantages to the Bank:</p> <ul style="list-style-type: none"> To deliver the quality of air is not more than the standard under OSHS-DOLE/OSHS Rule 1073, Table 8a: Mineral Dust: 10mg/m³. The bidder must comply to deliver the air quality standard inside the building. Bidder should meet the prescribe standard before and after cleaning and decontamination.

QUERY/CONCERN	CLARIFICATION
<p>produced by indoor renovations, repairs or other activities.</p> <p>The particles themselves are of different sizes, but the ones to be most concerned about are the smallest—10 micrometers or less in diameter—because they can be inhaled. Inhalation of PM can affect the heart and lungs.</p>	
<p>We want to confirm about the Terms of Payment for this project.</p>	<p>One-time payment after completion of all deliverables and upon issuance of Certificate of Completion by DBP.</p>

4. **The Eligibility, Technical and Financial Proposals must be properly tabbed for easy reference and must be submitted in sequence/order per Checklist of Requirements.**
5. **The BAC shall no longer entertain any question/request for clarification after the issuance of this Bid Bulletin.**
6. Please be advised that bids submitted after the deadline shall only be marked for recording purposes, shall not be included in the opening of bids, and shall be returned to the bidder unopened.

For the guidance and information of all concerned.

 SIGNED

ATTY. ERNESTO R. PURUGGANAN
 Vice President, and
 First Vice Chairperson, Bids and Awards Committee