



Bid Notice Abstract


Request for Quotation (RFQ)

Reference Number 12001518
Procuring Entity DEVELOPMENT BANK OF THE PHILIPPINES - BBG - NORTHERN MINDANA
Title Supply, Delivery and Installation of One (1) Lot Fire Detection Alarm System (FDAS)
Area of Delivery Surigao Del Norte

Solicitation Number:	2025 SUR 001	Status	Pending
Trade Agreement:	Implementing Rules and Regulations		
Procurement Mode:	Negotiated Procurement - Small Value Procurement (Sec. 53.9)	Associated Components	2
Classification:	Goods	Bid Supplements	0
Category:	Safety and Occupational Products		
Approved Budget for the Contract:	PHP 225,000.00	Document Request List	0
Delivery Period:	30 Day/s		
Client Agency:		Date Published	02/05/2025
Contact Person:	Richele S. Joloyohoy BAC Secretariat Tirso Neri St. corner Corrales Ave. Cagayan De Oro City Misamis Oriental Philippines 9000 63-088-8572088 nmbg@dbp.ph	Last Updated / Time	30/04/2025 09:25 AM
		Closing Date / Time	12/05/2025 15:00 PM
Description Kindly refer to the attached Technical Specification for details and other conditions. Other Information For further inquiries, please contact Ms. Cindy B. Basil Acting BSO, DBP Surigao Branch			

Created by Richele S. Joloyohoy
Date Created 30/04/2025

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.



SUPPLY, DELIVERY AND INSTALLATION OF ONE (1) LOT FIRE DETECTION ALARM SYSTEM (FDAS)

Item No.	Item and Description	Quantity	Unit/s	Unit Price	Total Price
1	Kindly refer to the attached Technical Specifications for details and other conditions	1	Lot		
	Total Amount				

(Sgd.) SM JONATHAN C. ABIAN
Head, Surigao Branch

(Indicate if VAT or VAT exempt)

DEVELOPMENT BANK OF THE PHILIPPINES (DBP)

TECHNICAL SPECIFICATIONS

Supply, Delivery and Installation of One (1) Lot Fire Detection Alarm System (FDAS) Small Value Procurement

- I. **Approved Budget for the Contract:** ₱ 225,000 (inclusive of VAT/applicable taxes and other charges)
- II. **Technical Specifications:** (per attached specifications)
- III. **Conditions of the Contract:**

1. The Supplier shall ensure that the items delivered are in accordance with the specifications required by the DBP. DBP has the right to reject the delivery if the item/s delivered were found to be defective and not according to the required specifications.
2. The DBP may terminate/cancel the Purchase Order (PO) when the Supplier fails to deliver, perform, and comply with its obligation.
3. **Delivery Period:** The Supplier shall deliver the items within Thirty (30) calendar days after the receipt of Notice to Proceed (NTP).

4. **Point of Delivery:**

Address	Contact No.	No. of Lots
DBP Surigao Branch Narciso Street Surigao City	(086) 826-0289	1

5. Interested Supplier/s must submit the following:
 - a. Proposal/Quotation
 - b. Proof of PhilGEPS Registration
 - c. 2025 Mayor's/Business Permit
 - d. Omnibus Sworn Statement
 - e. Secretary's Certificate (For supplier under partnership/corporation)
 - f. Signed Request for Quotation (RFQ)

IV. **Warranty and Retention:**

1. At least one (1) year warranty on parts and service upon receipt of unit/s by DBP
2. The Supplier warrants that the Goods under the Contract are new, unused, and free from defects.



DEVELOPMENT BANK OF THE PHILIPPINES
Head Office: San. Gil J. Puyat Avenue corner
Makati Avenue, Makati City, Philippines



TECHNICAL SPECIFICATION FIRE DETECTION ALARM SYSTEM FOR DBP SURIGAO BRANCH

FIRE ALARM CONTROL PANEL

- Number of addressable devices: ≥ 150
- Number of detector lines: 2 loop expandable
- Operating Voltage: 230V AC, 60Hz
- Output: 24V DC

AUTO DIALER (LINE / GSM READY)

- Operating voltage: 10 to 14V, DC
- Dialing method: Pulse or tone (Factory default = tone)
- Tel. Number memories: 4 x 16 digits for voice message sending, 1 x 26 Digits for pager numeric message sending
- Voice message duration: Max. 20 sec., recording is repeated for 40 sec., during sending
- Number of calls: When triggered, each programmed number is called ≥ 3 times

SMOKE DETECTOR (ADDRESSABLE)

- Type: Photoelectric Electronically addressable
- Alarm sensitivity: Built-in algorithm maps / NFPA Standards
- Indicator: Twin LED's (for 360° vision)
- Panel communication: Remotely (poll indicator)
- Operating voltage: 24V DC

PULL MANUAL SWITCH WITH ALARM BELL

- Minimum sound output: $\geq 70\text{dB}$
- Pull Manual Switch: Resettable via special key with non-breakable glass (to prevent from accidental activation)