



DEVELOPMENT BANK OF THE PHILIPPINES

Head Office: Sen. Gil J. Puyat Avenue corner
Makati Avenue, Makati City, Philippines

TECHNICAL SPECIFICATION

1.0HP INVERTER SPLIT TYPE AIR-CONDITIONING UNIT

- Capacity Indication : 1.0HP
- Mounting : Wall mounted
- Cooling Capacity(kJ/hr) : 7,250 – 12,000
- Power Consumption(Watts) : 490 – 1,200
- EER(kJ/W-hr) : 11.3 – 15.4
- DOE Star : ≥ 4.0
- Refrigerant Type : R32/R410A
- Voltage(V) : 230
- Phase(ϕ) : 1-Phase
- Frequency(Hz) : 60
- Inclusive of necessary accessories to operate the system

TECHNICAL SPECIFICATION OF AIR-CONDITIONING UNIT



(02) 8818-9511



info@dbp.ph



www.dbp.ph

P.O. Box 1996, Makati Central Post Office 1200
Makati City

Handwritten signature and initials.



DEVELOPMENT BANK OF THE PHILIPPINES

Head Office: Sen. Gil J. Puyat Avenue corner
Makati Avenue, Makati City, Philippines



TECHNICAL SPECIFICATION

2.0HP INVERTER SPLIT TYPE AIR-CONDITIONING UNIT

- Capacity Indication : 2.0HP
- Mounting : Wall mounted
- Cooling Capacity(kJ/hr) : 9,200 – 20,500
- Power Consumption(Watts) : 625 – 2,200
- EER(kJ/W-hr) : 11.3 – 15.4
- DOE Star : ≥ 4.0
- Refrigerant Type : R32/R410A
- Voltage(V) : 230
- Phase(ϕ) : 1-Phase
- Frequency(Hz) : 60
- Inclusive of necessary accessories to operate the system

TECHNICAL SPECIFICATION OF AIR-CONDITIONING UNIT



(02) 8818-9511



info@dbp.ph



www.dbp.ph



P.O. Box 1996, Makati Central Post Office 1200
Makati City

Handwritten signature

TECHNICAL SPECIFICATIONS

3.0HP WALL MOUNTED INVERTER SPLIT TYPE AIR-CONDITIONING SYSTEM

Specification:

- Mounting : Wall mounted
- Nominal Rating : 3.0HP
- Cooling Capacity (kJ/hr) : 11,500 to 32,000
- Power Consumption (Watts) : 725 to 2,620
- Voltage (V) : 230
- Phase (Φ) : Single-phase or 3-phase (depending to the branch's phase system)
- Frequency (Hz) : 60
- Refrigerant Type : R32

Inclusive of necessary accessories to operate the system



DEVELOPMENT BANK OF THE PHILIPPINES

Head Office: Sen. Gil J. Puyat Avenue corner
Makati Avenue, Makati City, Philippines



BAGONG PILIPINAS

TECHNICAL SPECIFICATION

3.0TR INVERTER FLOOR MOUNTED AIR-CONDITIONING UNIT

- Capacity Indication : 3.0TR
- Mounting : Floor Mounted
- Cooling Capacity(kJ/hr) : 14,300 – 40,000
- Power Consumption(Watts) : 740 – 3,640
- EER(kJ/W-hr) : 11.3 – 15.4
- DOE Star : ≥ 4.0
- Refrigerant Type : R32/R410A
- Voltage(V) : 230
- Phase(ϕ) : 1-Phase
- Frequency(Hz) : 60
- Inclusive of necessary accessories to operate the system

TECHNICAL SPECIFICATION OF AIR-CONDITIONING UNIT



(02) 8818-9511



info@dbp.ph



www.dbp.ph



P.O. Box 1996, Makati Central Post Office 1200
Makati City