



DEVELOPMENT BANK OF THE PHILIPPINES
BBG – NORTHERN MINDANAO
3F DBP Cagayan de Oro Bldg., T. Neri St. corner
Corrales Ave., Cagayan de Oro City, Philippines



BAGONG PILIPINAS

**Bid Bulletin No. 1
September 16, 2025**

**ONE (1) LOT SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING
OF 2KVA, 6KVA, AND 10KVA UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR
VARIOUS BBG-NORTHERN MINDANAO BRANCHES
BID REFERENCE NO. 2025-001**

This Bid Bulletin No. 1 is issued to modify, amend or clarify items in the issued Bidding Documents. This shall form an integral part of the said Bidding Documents.

REVISED BIDDING FORM

Item	Reference (FROM)	Amendment/Change/Clarification\ (TO)
1	Section III. Bid Date Sheet Referring to page 46: ITB Clause 16.1 The Bid Security shall be in the form of a Bid Securing Declaration, and any of the following [<i>choose at least two (2)</i>]:	The Bid Security shall be in the form of a Bid Securing Declaration, and any of the following [<i>choose at least one (1)</i>]:
2	Section VII. Technical Specifications Referring to page 72: TECHNICAL SPECIFICATIONS (ANNEX A)	<u>ADDITIONAL SPECIFICATIONS:</u> 1. Single-phase or three-phase configuration - 2KVA & 6KVA - Single phase but for 10KVA, since it is a replacement of existing unit, we kindly ask the prospective supplier to conduct an actual inspection of the existing unit to verify the accurate Phase System of the UPS. 2. Number of batteries included - Battery runtime: 2KVA ≥ 30 minutes per 375W, 6KVA ≥ 15 minutes at Full load and 10KVA ≥ 15 minutes at Full load 3. Online or offline type - Since it is replacement of existing unit, we kindly ask the prospective supplier to conduct an actual inspection of the existing unit to verify the same type of UPS.



(02) 8818-9511



info@dbp.ph



www.dbp.ph



P.O. Box 1996, Makati Central Post Office 1200
Makati City

3	Section VII. Technical Specifications			
	Referring to page 73: SCOPE OF WORKS			
	Description	Total Quantity	Description	Total Quantity
	2KVA Uninterruptible Power Supply	5 units	2KVA Uninterruptible Power Supply	8 units
	6KVA Uninterruptible Power Supply	13 units	6KVA Uninterruptible Power Supply	10 units
4	10KVA Uninterruptible Power Supply	6 units	10KVA Uninterruptible Power Supply	6 units
	Section VIII. Philippine Bidding Document Related Forms			
	Referring to page 90: FORM 5 (page 2 of 2) Bid Securing Declaration Item 3.c.			
	<i>"I am/we are declared the bidder with the [Insert Award Criterion1] and I/we have furnished the performance security and signed the Contract."</i>		<i>"I am/we are declared the bidder with the Pass or Fail Criterion and I/we have furnished the performance security and signed the Contract."</i>	
5	Section VIII. Philippine Bidding Document Related Forms			
	Referring to page 93: FORM 8 (page 1 of 2) Certificate of Net Financial Contracting Capacity			
		Year 2023		Year 2024
	1. Current Assets		4. Current Assets	
	2. Current Liabilities		5. Current Liabilities	
	3. Current Net Worth/Net Working Capital (Item 1 minus Item 2)		6. Current Net Worth/Net Working Capital (Item 1 minus Item 2)	

In case of additional queries, please write the RBAC Secretariat at the following e-mail address: nmbg@dbp.ph.

For the guidance and information of all concerned.

(SGD.) AVP FRANCIS R. DONGOGAN
RBAC Chairperson

Received by:

Name and Signature of the Representative

Name of Company